

Asset Performance Statistics

Black Point Hong Kong

- Gas-fired power station
- 2,500MW (8 x 312.5MW)
- Plant commissioned between 1996 and 2006
- Shareholding of 70% with operational control by CLP



Parameter	Unit	2015	2014	2013	2012	2011
1. Operation						
Electricity sent out	GWh	8,899	5,315	5,675	6,787	7,311
Gas consumed	TJ	71,364	42,433	45,141	50,408	57,639
Oil consumed	TJ	117	148	146	3,644	39
Thermal efficiency	%	44.8	44.9	45.1	45.2	45.6
Equivalent availability factor (EAF)	%	84.8	86.7	86.1	83.4	85.9
2. Air Emissions						
CO ₂ e (Scope 1) ⁽¹⁾	KT	3,688	2,295	2,455	3,065	3,228
CO ₂ (Scope 1) ⁽¹⁾	KT	3,673	2,285	2,447	3,056	3,220
SO ₂	KT	0.05	0.07	0.08	0.12	0.13
NO _x	KT	1.5	0.9	1.1	1.5	1.5
Particulate (Total)	KT	0.06	0.03	0.04	0.05	0.05
Particulate (Respirable)	KT	0.06	0.03	0.04	0.05	0.05
3. Water						
Water Withdrawal	Mm ³	931.2	612.5	668.3	720.9	743.2
from marine water resources	Mm ³	930.9	612.3	668.1	720.6	742.9
from freshwater resources ⁽²⁾	Mm ³	-	-	-	-	-
from municipal sources	Mm ³	0.3	0.2	0.3	0.3	0.2
Water Discharged	Mm ³	931.0	612.4	668.2	720.7	743.0
cooling water discharged to sea	Mm ³	930.9	612.3	668.1	720.6	742.9
treated wastewater discharged to sea	Mm ³	0.1	0.1	0.1	0.1	0.1
treated wastewater discharged to freshwater bodies ⁽²⁾	Mm ³	-	-	-	-	-
wastewater discharged to sewerage ⁽³⁾	Mm ³	-	-	-	-	-
Water Reused / Recycled	Mm ³	-(4)	-(4)	-(4)	-(4)	0
4. Environmental Compliance						
Regulatory non-compliances resulting in fines or prosecutions	No.	0	0	0	0	0
Licence limit exceedances & other non-compliances	No.	0	0	0	0	0

Asset Performance Statistics

Black Point Hong Kong

- Gas-fired power station
- 2,500MW (8 x 312.5MW)
- Plant commissioned between 1996 and 2006
- Shareholding of 70% with operational control by CLP



Parameter	Unit	2015	2014	2013	2012	2011
5. Waste Management ⁽⁵⁾						
Hazardous waste						
produced	T (solid) / kl (liquid)	76 / 97	22 / 967	19 / 92	15 / 270	192 / 136
recycled	T (solid) / kl (liquid)	58 / 65	0.3 / 141	0.1 / 80	0.4 / 270	0.4 / 136
disposed	T (solid) / kl (liquid)	18 / 33	22 / 826	19 / 12	15 / 0	191 / 0
Non-hazardous waste						
produced	T (solid) / kl (liquid)	3,438 / 0	12,509 / 0	1,566 / 0	3,151 / 0	212 / 0
recycled	T (solid) / kl (liquid)	485 / 0	715 / 0	682 / 0	407 / 0	150 / 0
disposed	T (solid) / kl (liquid)	2,953 / 0	11,794 / 0	884 / 0	2,744 / 0	62 / 0
6. Safety ⁽⁶⁾						
Employee - Fatalities	No.	0	0	0	0	0
Employee - Days lost / charged	Days	0	0	0	62	12
Employee - Lost Time Injuries ⁽⁷⁾	Cases	0	0	-	-	-
Employee - Occupational Disease ⁽⁷⁾	Cases	0	0	-	-	-
Employee - Total Work Hours ⁽⁷⁾	Manhours	1,815,968	1,858,816	-	-	-
Contractor - Fatalities ⁽⁷⁾	No.	0	0	-	-	-
Contractor - Lost Time Injuries ⁽⁷⁾	Cases	2	0	-	-	-
Contractor - Total Work Hours ⁽⁷⁾	Manhours	3,980,288	4,343,822	-	-	-

Notes:

(1) Scope 2 emissions are included in Scope 1 as electricity consumed was generated within CLP Power Hong Kong's own organisational boundary.

(2) Not applicable to Black Point.

(3) Not applicable as wastewater is treated on site and discharged to sea. There is no discharge to sewerage.

(4) Some treated wastewater is reused on site but measurement data are not routinely collected.

(5) Waste categorised in accordance with local regulations. Contractor waste is included. Quantity includes waste arising from Penny's Bay Power Station (hazardous waste during 2010-2013, non-hazardous waste during 2010-2012).

(6) All safety and employee data are combined for the three power stations under Castle Peak Power Company (CAPCO).

(7) Started reporting in 2014.

2015 data have been independently reviewed by the Hong Kong Quality Assurance Agency (HKQAA).