

Laiwu I

- Wind farm
- 49.5MW generation capacity
- Station commissioned in 2014
- Wholly owned and operated by CLP

| Parameter | Unit | 2017 | 2016 | 2015 |
|---|----------|--------|--------|--------|
| 1. Operation | | | | |
| Electricity sent out ⁽¹⁾ | GWh | 69 | 75 | 64 |
| Equivalent Availability factor (EAF) ⁽²⁾ | % | 99.8 | 99.7 | 99.6 |
| Gross Capacity factor ⁽³⁾ | % | 16.5 | 17.1 | 14.9 |
| 2. Environmental Compliance | | | | |
| Regulatory non-compliances resulting in fines or prosecutions | No. | 0 | 0 | 0 |
| Licence limit exceedances & other non-compliances | No. | 0 | 0 | 0 |
| 3. Water & Waste ^{(4) (5)} | | | | |
| 4. Safety | | | | |
| Employee | | | | |
| Fatalities | No. | 0 | 0 | 0 |
| Days lost / charged | Days | 0 | 0 | 0 |
| Lost Time Injuries | Cases | 0 | 0 | 0 |
| Occupational Disease | Cases | 0 | 0 | 0 |
| Total Work Hours | Manhours | 53,256 | 56,080 | 43,936 |
| Contractor | | | | |
| Fatalities | No. | 0 | 0 | 0 |
| Lost Time Injuries | Cases | 0 | 0 | 0 |
| Total Work Hours | Manhours | 37,339 | 32,200 | 20,712 |

Notes:

⁽¹⁾ Electricity sent out has been reported since 2017. Prior to 2017, Electricity sold was reported.

⁽²⁾ Equivalent availability factor has been reported since 2017. Prior to 2017, Availability factor was reported.

⁽³⁾ Gross capacity factor has been reported since 2017. Prior to 2017, Capacity factor was reported.

⁽⁴⁾ Water consumed and discharged is for domestic use only and the quantity is negligible.

⁽⁵⁾ Waste produced is domestic waste only and the quantity is negligible.