

Sandu I

- Wind farm
- 99MW generation capacity
- Station commissioned in 2016
- Wholly owned and operated by CLP

Parameter	Unit	2017
1. Operation		
Electricity sold	GWh	238
Equivalent Availability factor (EAF)	%	99.8
Gross Capacity factor	%	27.5
2. Environmental Compliance		
Regulatory non-compliances resulting in fines or prosecutions	No.	0
Licence limit exceedances & other non-compliances	No.	0
3. Water & Waste ^{(1) (2)}		
4. Safety		
Employee		
Fatalities	No.	0
Days lost / charged	Days	0
Lost Time Injuries	Cases	0
Occupational Disease	Cases	0
Total Work Hours	Manhours	49,272
Contractor		
Fatalities	No.	0
Lost Time Injuries	Cases	0
Total Work Hours	Manhours	42,280

Notes:

⁽¹⁾ Water consumed and discharged is for domestic use only and the quantity is negligible.

⁽²⁾ Waste produced is domestic waste only and the quantity is negligible.