

Xundian I

- Wind farm
- 49.5MW generation capacity
- Station commissioned in 2016
- Wholly owned and operated by CLP

Parameter	Unit	2017	2016
1. Operation			
Electricity sent out ⁽¹⁾	GWh	127	135
Equivalent availability factor (EAF) ⁽²⁾	%	99.4	99.6
Gross Capacity factor ⁽³⁾	%	29.2	31.9
2. Environmental Compliance			
Regulatory non-compliances resulting in fines or prosecutions	No.	0	0
Licence limit exceedances & other non-compliances	No.	0	0
3. Water & Waste^{(4) (5)}			
4. Safety			
Employee			
Fatalities	No.	0	0
Days lost / charged	Days	0	0
Lost Time Injuries	Cases	0	0
Occupational Disease	Cases	0	0
Total Work Hours	Manhours	51,320	37,188
Contractor			
Fatalities	No.	0	0
Lost Time Injuries	Cases	0	0
Total Work Hours	Manhours	21,604	56,728

Notes:

⁽¹⁾ Electricity sent out has been reported since 2017. Prior to 2017, Electricity sold was reported.

⁽²⁾ Equivalent availability factor has been reported since 2017. Prior to 2017, Availability factor was reported.

⁽³⁾ Gross capacity factor has been reported since 2017. Prior to 2017, Capacity factor was reported.

⁽⁴⁾ Water consumed and discharged is for domestic use only and the quantity is negligible.

⁽⁵⁾ Waste produced is domestic waste only and the quantity is negligible.