Asset Performance Statistics

Jhajjar

- Coal-fired power station
- 1,320MW (2x660MW)
- Plant commissioned in 2012
- Wholly owned and operated by CLP



| | 11. 14 | 2014 | 2045 | 2011 | 2042 |
|---|--------|--------|--------|--------|---------------------|
| Parameter | Unit | 2016 | 2015 | 2014 | 2013 |
| 1. Operation | | | | | |
| Electricity sent out | GWh | 2,965 | 5,406 | 5,877 | 5,375 |
| Coal consumed | TJ | 30,750 | 53,591 | 58,963 | 52,731 |
| Oil consumed | TJ | 103 | 71 | 36 | 21 |
| Thermal efficiency | % | 34.7 | 36.3 | 35.9 | 37.2 |
| Equivalent availability factor (EAF) | % | 93.2 | 82.5 | 80.0 | 89.5 |
| | | | | | |
| 2. Air Emissioins | | | | | |
| CO₂e (Scopes 1 & 2) | kT | 2,805 | 4,852 | 5,331 | 5,015 |
| CO ₂ (Scopes 1 & 2) | kT | 2,788 | 4,826 | 5,302 | 4,988 |
| SO ₂ | kT | 12.0 | 11.9 | 18.9 | 15.8 |
| NO _x | kT | 4.0 | 4.7 | 7.1 | 4.8 |
| Particulates (Total) | kT | 1.3 | 2.6 | 4.3 | 0.6 |
| | | | | | |
| 3. Water | | | | | |
| Water Withdrawal | Mm^3 | 7.5 | 10.9 | 13.1 | 13.0 |
| from marine water resources ⁽¹⁾ | Mm³ | - | - | - | - |
| from freshwater resources | Mm^3 | 7.5 | 10.9 | 13.1 | 13.0 ⁽²⁾ |
| from municipal sources ⁽¹⁾ | Mm^3 | - | - | - | - |
| Water Discharged | Mm³ | 0 | 0 | 0 | 0 |
| cooling water blowdown discharged (3) | Mm³ | - | - | - | - |
| treated wastewater discharged ⁽³⁾ | Mm³ | - | - | - | - |
| Water Reused / Recycled | Mm^3 | 37.0 | 54.2 | 66.2 | _(4) |
| | | | | | |
| 4. Environmental Compliance | | | | | |
| Regulatory non-compliances resulting in fines or prosecutions | No. | 0 | 0 | 0 | 0 |
| Licence limit exceedances & other non-compliances | No. | 2 | 12 | 1 | 2 |
| | | | | | |

Asset Performance Statistics

- Coal-fired power station
- 1,320MW (2x660MW)
- Plant commissioned in 2012
- Wholly owned and operated by CLP



| 5. By-products & Waste Management | | | | | |
|--|----------------------------|-----------|-----------|-----------|--------|
| Ash produced | kT | 753 | 1,179 | 1,139 | 1,023 |
| Ash recycled / sold | kT | 587 | 1,078 | 993 | 868 |
| Gypsum produced | kT | 0 | 8.1 | 0.4 | 5 |
| Gypsum recycled / sold | kT | 0 | 8.1 | 0.4 | 5 |
| Hazardous waste ⁽⁵⁾ | | | | | |
| produced | T (solid) / kl (liquid) | 149 / 49 | 130 / 15 | 3 / 60 | 0/7 |
| recycled | T (solid) / kl (liquid) | 12 / 49 | 15 / 15 | 3 / 60 | 0/7 |
| disposed | T (solid) / kl (liquid) | 136 / 0 | 115 / 0 | 0/0 | 0/0 |
| Non-hazardous waste ⁽⁵⁾ | | | | | |
| produced | T (solid) / kl (liquid) | 624 / 0 | 867 / 0 | 891 / 0 | 60 / 0 |
| recycled | T (solid) / kl (liquid) | 624 / 0 | 867 / 0 | 891 / 0 | 0/0 |
| disposed | T (solid) / kl (liquid) | 0/0 | 0/0 | 0/0 | 60 / 0 |
| | | | | | |
| 6. Safety | | | | | |
| Employee - Fatalities | No. | 0 | 0 | 0 | 0 |
| Employee - Days lost / charged | Days | 0 | 22 | 0 | 8 |
| Employee - Lost Time Injuries ⁽⁶⁾ | Cases | 0 | 1 | 0 | - |
| Employee - Occupational Disease ⁽⁶⁾ | Cases | 0 | 0 | 0 | - |
| Employee - Total Work Hours ⁽⁶⁾ | Manhours | 457,320 | 390,776 | 487,688 | - |
| Contractor - Fatalities ⁽⁶⁾ | No. | 1 | 0 | 0 | - |
| Contractor - Lost Time Injuries ⁽⁶⁾ | Cases | 1 | 1 | 4 | - |
| Contractor - Total Work Hours ⁽⁶⁾ | Manhours | 3,537,216 | 3,480,904 | 3,421,256 | - |
| | | | | | |

2016 data have been independently verified by DNV GL Business Assurance India Pvt Limited.

Notes:
(1) Not applicable to Jhajjar.
(2) Data updated to align with reporting definition.
(3) All wastewater is treated and reused on site, no wastewater is being discharged out of site boundary.
(4) No measurement data are routinely collected.
(5) Waste categorised in accordance with local regulations. Contractor waste is included.
(6) Started reporting in 2014.