

Asset Performance Statistics

Penny's Bay

- Diesel-fired power station (backup facility providing quick-start support)
- 300MW (3 x 100MW)
- Plant commissioned in 1992
- Shareholding of 70% with operational control by CLP



Parameter	Unit	2016	2015	2014	2013	2012
1. Operation						
Electricity sent out	GWh	1.0	0.6	1.0	0.1	3.9
Oil consumed	TJ	18	11	16	5	61
Thermal efficiency	%	21.1	19.0	21.5	10.1	23.3
Equivalent availability factor (EAF)	%	98.9	100.0	95.7	100	91.9
2. Air Emissions						
CO ₂ e (Scope 1) ⁽¹⁾	kT	1.3	1.7	1.6	0.3	4.4
CO ₂ (Scope 1) ⁽¹⁾	kT	1.2	0.8	1.1	0.3	4.1
SO ₂	kT	0.000005	0.000004	0.000008	0.000002	0.000005
NO _x	kT	0.0018	0.0012	0.0017	0.0005	0.006
Particulate (Total)	kT	0.00003	0.00002	0.00003	0.00001	0.0001
Particulate (Respirable)	kT	0.00003	0.00002	0.00003	0.00001	0.0001
3. Water						
Water Withdrawal	Mm ³	0.0006	0.0007	0.0008	0.0007	0.0007
from marine water resources ⁽²⁾	Mm ³	-	-	-	-	-
from freshwater resources	Mm ³	0.0001	0 ⁽³⁾	0 ⁽³⁾	0 ⁽³⁾	0.0001
from municipal sources	Mm ³	0.0005	0.0007	0.0008	0.0007	0.0007
Water Discharged	Mm ³	0	0	0	0	0
treated wastewater discharged to sea	Mm ³	0	0	0	0	0
treated wastewater discharged to freshwater bodies ⁽²⁾	Mm ³	-	-	-	-	-
wastewater discharged to sewerage ⁽⁴⁾	Mm ³	-	-	-	-	-
Water Reused / Recycled	Mm ³	0	0	0	0	0
4. Environmental Compliance						
Regulatory non-compliances resulting in fines or prosecutions	No.	0	0	0	0	0
Licence limit exceedances & other non-compliances	No.	0	0	0	0	0

Penny's Bay

- Diesel-fired power station (backup facility providing quick-start support)
- 300MW (3 x 100MW)
- Plant commissioned in 1992
- Shareholding of 70% with operational control by CLP



5. Waste Management ⁽⁵⁾						
Hazardous waste						
produced	T (solid) / kl (liquid)	0 / 1	0 / 23	0 / 8	-	-
recycled	T (solid) / kl (liquid)	0 / 0	0 / 23	0 / 8	-	-
disposed	T (solid) / kl (liquid)	0 / 1	0 / 0	0 / 0	-	-
Non-hazardous waste						
produced	T (solid) / kl (liquid)	10 / 0	30 / 0	37 / 0	12 / 0	-
recycled	T (solid) / kl (liquid)	0 / 0	0 / 0	4 / 0	0 / 0	-
disposed	T (solid) / kl (liquid)	10 / 0	30 / 0	32 / 0	12 / 0	-
6. Safety ⁽⁶⁾						
Employee - Fatalities	No.	0	0	0	0	0
Employee - Days lost / charged	Days	0	0	0	0	62
Employee - Lost Time Injuries ⁽⁷⁾	Cases	0	0	0	-	-
Employee - Occupational Disease ⁽⁷⁾	Cases	0	0	0	-	-
Employee - Total Work Hours ⁽⁷⁾	Manhours	1,870,155	1,815,968	1,858,816	-	-
Contractor - Fatalities ⁽⁷⁾	No.	0	0	0	-	-
Contractor - Lost Time Injuries ⁽⁷⁾	Cases	0	2	0	-	-
Contractor - Total Work Hours ⁽⁷⁾	Manhours	4,358,061	3,980,288	4,343,822	-	-

Notes:

(1) Scope 2 emissions are included in Scope 1 as electricity consumed was generated within CLP Power Hong Kong's own organisational boundary.

(2) Not applicable to Penny's Bay.

(3) The quantity of water withdrawal from freshwater resources is negligible.

(4) Wastewater is collected by licenced collector to government sewage treatment facility for treatment and no measurement data is available.

(5) Waste categorised in accordance with local regulations. Contractor waste is included. Waste arising from

Penny's Bay Power Station is reported separately from Black Point Power Station (hazardous waste since 2014, and non-hazardous waste since 2013).

(6) All safety data are combined for the three power stations under Castle Peak Power Company (CAPCO).

(7) Started reporting in 2014.

2016 data have been independently reviewed by the Hong Kong Quality Assurance Agency (HKQAA).